



Power Systems Electric, Inc.

Emergency Generator Systems

885 S. RAILROAD ST.

MYERSTOWN, PA 17067-1516

PHONE (717) 933-5617

Persuent to NFPA 110-16 recomendation/requirement for Diesel Fuel testing.

Power Systems Electric Inc. Offers Lab testing of Diesel Fuel per NFPA 110-16 8.3.7
States: A fuel quality test shall be performed at least annually using appropriate ASTM standards

The following tests which are encompassed in the D975 test are performed -

Test	Methods
Distillation - 50%	ASTM D86-08a
Distillation - 90%	ASTM D86-08a
Flash Point	ASTM D93-10
Water by Karl Fischer	ASTM D6304-07
Water and Sediment	ASTM D2709
API Gravity by Hydrometer	ASTM D1298-99
Appearacne	ASTM D4176-97
Centane Index	ASTM D976-01
Microbial Growth	Micro/Culture Medium
Copper Strip Corrosion	ASTM D130-04
Sulfur	ASTM D5453-09

A Certificate of Analysis will be provided for your records
Contact us for pricing and or to add this to your maintenance program.